

A Spark Neglected
Burn The House.



HO : A to Z Marketing & Services
Ward No.-14, Amarkantak Road,
Dhanpuri, Distt. - Shahdol (M.P.)
PIN - 484114
Mo. : 999-333-98-98
atozmarketingdnp@gmail.com

GSTIN : 23BUZPS3929J2ZQ

B.O. : Rewa, Bilaspur, Singrauli

Ref. : A2Z/24-25/355

Date 21/12/2024


Our Speciality



Fire & Safety Products



Petrol Pump Accessories



CCTV & Securities



GPS & VTS



Fire Alarm System



Computer & IT

General & Technical Material

TEST REPORT of Your FIRE EXTINGUISHER

To,

M/s- SCHOOL D.A.V. BURHAR PUBLIC
SCHOOL
BURHAR DISTT-SHAHDOL (M.P.)

Dear Sir,

Our Firm authorized service engineer has checked the pressure by hydraulic machine of Fire Extinguisher (only stored pressure type) cylinders 430 pound in 35kg. & for CO2 type Fire Extinguisher tested by 2.30 minutes per 250 kgs.

FIRE EXTINGUISHER- MAKE BY- NA -

	Qty.	Status/Action/Remark
ABC Type 04.Kg.	03.No.	Refilled, checked & Tested OK.
ABC Type 1.Kg.	1.No.	Refilled, checked & Tested OK.
DCP Type 10.Kg.	10.No.	Refilled, checked & Tested OK.
DCP Type 1.Kg.	1.No.	Refilled, checked & Tested OK.
CO2 Type 4.5Kg.	02.No.	Refilled, checked & Tested OK.
CO2 Type 1.Kg.	1.No.	Refilled, checked & Tested OK.
FOAM Type 09.Ltr.	01.No.	Refilled, checked & Tested OK.

Refilling Status:-

Inspection Date :- 21/Dec/2024
Refilling Date :- 21/Dec/2024
Next Due Date :- 20/Dec/2025

Thanking you with warm regards,

Proprietor
Marketing & Services
Proprietor

Inspected/Services By
Abheshak Pratap Singh
Fire & Safety Engineer

सुरक्षा मतलब

✓ सही चीज

✓ सही तरह से

✓ सही समय पर करना है।